

### Trip indicator switch, 2 N/C, screw connection

Part no. AGM2-01-PKZ0
Catalog No. 072899
Eaton Catalog No. XTPAXSATR02





Call to Order 717-209-7100

# **Delivery program**

2 cm c, program	
Product range	Accessories
Accessories	Trip-indicating auxiliary contacts
	Can be retrofitted on the right side of motor-protective circuit-breakers Differential status indication a) General trip indication (overload) b) Short-circuit release Short-circuits indicated locally by means of a red indicator that can be manually reset
For use with	Trip indicator PKZ0(4), PKE
Contacts	
N/C = Normally closed	2 x 1 NC
Contact diagram	On/off    L11213
	Trip "+"  U11213 ——————————————————————————————————
Contact sequence	431 431
For use with	PKZM0 PKZM4 PKZM0-T PKM0 PKZM01 PKE
Can be combined with auxiliary contact	NHI11-PKZ0 NHI12-PKZ0 NHI21-PKZ0 NHI-E

### **Technical data**

### **Auxiliary contacts**

Rated impulse withstand voltage	$U_{imp}$	V AC	6000
Overvoltage category/pollution degree			III/3
Rated operational voltage	U <sub>e</sub>	V	
	U <sub>e</sub>	V AC	500
	U <sub>e</sub>	V DC	250
Safe isolation to EN 61140			
Between auxiliary contacts and main contacts		V AC	690

Rated operational current	I <sub>e</sub>	Α	
AC-15			
220 - 240 V	I <sub>e</sub>	Α	3.5
380 - 415 V	I <sub>e</sub>	Α	2
440 V 500 V	I <sub>e</sub>	Α	1
DC-13 L/R - 100 ms			
24 V	I <sub>e</sub>	Α	2
60 V	I <sub>e</sub>	Α	1
110 V	I <sub>e</sub>	Α	0.5
220 V	I <sub>e</sub>	Α	0.25
Lifespan		S	
Lifespan, mechanical	Operations	x 10 <sup>6</sup>	> 0.01
Lifespan, electrical	Operations	x 10 <sup>6</sup>	0.05
Control circuit reliability	Failure rate	λ	$<10^{-8}, <$ one failure at 100 million operations (at Ue = 24 V DC, Umin = 17 V, Imin = 5.4 mA)
Short-circuit rating without welding			
Fuseless		Туре	FAZ-B4/1-HI
Fuse		A gG/gL	10
Terminal capacities			
Solid or flexible conductor, with ferrule		$\text{mm}^2$	0,75 - 2,5
Solid or stranded		AWG	18 - 14

**Design verification as per IEC/EN 61439** 

Jesign verification as per IEG/EIN 61439			
Fechnical data for design verification			
Rated operational current for specified heat dissipation	In	Α	3.5
Heat dissipation per pole, current-dependent	P <sub>vid</sub>	W	0.1
Equipment heat dissipation, current-dependent	P <sub>vid</sub>	W	0
Static heat dissipation, non-current-dependent	P <sub>vs</sub>	W	0
Heat dissipation capacity	P <sub>diss</sub>	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	55
C/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $ \frac{1}{2} \left( \frac{1}{2} \right) = \frac{1}{2} \left( \frac{1}{2} \right) \left($			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.


# **Technical data ETIM 6.0**

Low-voltage industrial components (EG000017) / Auxiliary contact block (EC000041)			
Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Auxiliary switch block (ecl@ss8.1-27-37-13-02 [AKN342010])			
Number of contacts as change-over contact 0			
Number of contacts as normally open contact			0
Number of contacts as normally closed contact			2
Rated operation current le at AC-15, 230 V		Α	3.5
Type of electric connection			Screw connection
Model			Top mounting
Mounting method			Side mounting

# **Approvals**

The second secon	
Product Standards	UL 508; CSA-C22.2 No. 14; IEC60947-4-1; CE marking
UL File No.	E36332
UL Category Control No.	NLRV
CSA File No.	165628
CSA Class No.	3211-05
North America Certification	UL listed, CSA certified
Specially designed for North America	No

# **Dimensions**



# **Additional product information (links)**

IL03402030Z (AWA1210-1328) Trip-indicating auxiliary contact for PKZM0			
IL03402030Z (AWA1210-1328) Trip-indicating auxiliary contact for PKZM0 ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL03402030Z2010_10.pdf			
IL03402034Z (AWA1210-1945) Motor-protective circuit-breaker, Starter			
IL03402034Z (AWA1210-1945) Motor-protective circuit-breaker, Starter	ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL03402034Z2016_06.pdf		
Motor starters and "Special Purpose Ratings" for the North American market	http://www.moeller.net/binary/ver_techpapers/ver953en.pdf		
Busbar Component Adapters for modern Industrial control panels	http://www.moeller.net/binary/ver_techpapers/ver960en.pdf		